

Reference

NBS
Publi-
cations



A11104 498386

100



QC
100
U56
78-1563

NBSIR 78-1568

Economic Analysis of the Norris Cotton Federal Office Building

Phillip T. Chen

Center for Building Technology
National Engineering Laboratory
National Bureau of Standards
U.S. Department of Commerce
Washington, D.C. 20234

Sponsored by:
The Department of Energy
Washington, D.C. 20461

NOVEMBER 1978

MAY 14 1979

NBSIR 78-1568

ECONOMIC ANALYSIS OF THE NORRIS COTTON FEDERAL OFFICE BUILDING

Phillip T. Chen

Building Economics and Regulatory Technology Division
Center for Building Technology
National Engineering Laboratory
National Bureau of Standards
Washington, D.C. 20234

November 1978

Sponsored by:
The Department of Energy
Washington, D.C. 20461



U.S. DEPARTMENT OF COMMERCE, Juanita M. Kreps, Secretary

Dr. Sidney Harman, Under Secretary

Jordan J. Baruch, Assistant Secretary for Science and Technology

NATIONAL BUREAU OF STANDARDS, Ernest Ambler, Director

PREFACE

This study was conducted by the Applied Economics Program of the National Bureau of Standards for the Department of Energy to demonstrate how economic analysis can be applied to the post-occupancy evaluation of the Norris Cotton Federal Office Building, owned and operated by the General Services Administration as an energy conserving building. Drs. Harold E. Marshall and Stephen F. Weber and Mr. Robert E. Chapman provided reviews of the economic aspects of this paper. Drs. James E. Hill and Stanley T. Liu and Mr. Thomas E. Richtmyer furnished thermal engineering data. Mr. G. G. Wells reviewed the architectural and cost aspects of this study. Mr. Gerald K. Farrington provided building operation and energy consumption data. Ms. Kimberly A. Hockenbery made cost calculations. The author wishes to express his appreciation to the above persons without whose help this study could not have been completed.

ABSTRACT

The Norris Cotton Federal Office Building in Manchester, New Hampshire, has been constructed and occupied by the General Services Administration to demonstrate energy conservation techniques in the design and operation of a contemporary office building. This post occupancy economic evaluation conducted by the National Bureau of Standards shows that additional construction costs incurred in order to reduce the energy consumption of the building are adequately offset by the present value of the resulting annual energy savings. In the economic model, the actual construction cost and energy consumption of the constructed building are compared with the estimated construction cost and energy consumption of a hypothetical equivalent conventional building. The present value costs of the two buildings are calculated for each year during a 40-year study period.

Keywords: Building design; construction cost estimation; discounted payback period; economic analysis; economic evaluation; energy conservation; life-cycle costing; present value analysis.

TABLE OF CONTENTS

	Page
PREFACE.....	iii
ABSTRACT.....	iv
LIST OF TABLES AND FIGURES.....	vi
SI CONVERSION UNITS.....	vii
1.0 INTRODUCTION.....	1
1.1 Purpose.....	2
1.2 Scope and Approach.....	2
1.3 Organization.....	3
2.0 CONSTRUCTION COST AND ENERGY CONSUMPTION.....	4
2.1 Equivalent Conventional Building (ECB).....	4
2.2 Building Construction Costs.....	5
2.3 Annual Energy Consumption.....	5
3.0 ECONOMIC EVALUATION.....	10
3.1 Life-Cycle Cost Model.....	10
3.2 Data Assumptions.....	11
3.3 Economic Comparison.....	11
4.0 SUMMARY AND RECOMMENDATION FOR FURTHER RESEARCH.....	21
4.1 Summary.....	21
4.2 Recommendation for Further Research.....	21
APPENDIX A BUILDING DESIGN AND COST DATA.....	A-1
APPENDIX B ENERGY USAGE AND PRICE DATA.....	B-1
APPENDIX C YEAR-BY-YEAR PRESENT VALUE COSTS.....	C-1
REFERENCES.....	D-1

LIST OF TABLES

	PAGE
2.1 BUILDING CONSTRUCTION COSTS IN 1976 DOLLARS.....	6
2.2 ANNUAL ENERGY CONSUMPTION FOR NORRIS COTTON FEDERAL OFFICE BUILDING (NCFOB) IN 10^9 BTU AND 1977 DOLLARS.....	7
2.3 ANNUAL ENERGY CONSUMPTION FOR ECB IN 10^9 BTU AND 1977 DOLLARS.	9
3.1 ESTIMATED ANNUAL PERCENTAGE INCREASE IN REAL ENERGY PRICES....	12
3.2 PRESENT VALUE COSTS AND CALCULATION OF PRESENT VALUE SAVINGS (\$1,000).....	13
3.3 PRESENT VALUE COSTS AND SAVINGS WITH MODIFIED ENERGY CONSUMPTION FOR ECB (\$1,000).....	15

LIST OF FIGURES

3.1 CASE I Present Value Cost Vs. Lifespan for NCFOB & ECB.....	17
3.2 CASE II Present Value Cost Vs. Lifespan for NCFOB & ECB.....	18
3.3 CASE III Present Value Cost Vs. Lifespan for NCFOB & ECB.....	19
3.4 CASE IV Present Value Cost Vs. Lifespan for NCFOB & ECB.....	20

SI Conversion Units

In view of the present accepted practice in this country for building technology, common U.S. units of measurement have been used throughout this publication. In recognition of the position of the United States as a signatory to the General Conference of Weights and Measures, which gave official status to the metric SI system of units in 1960, appropriate conversion factors have been provided in the table below. The reader interested in making further use of the coherent system of SI units is referred to:

NBS SP330, 1972 Edition, "The International System of Units"
E380-72 ASTM Metric Practice Guide (American National Standard
Z210.1)

Table of Conversion Factors in Metric (S.I.) Units

Physical Quantity (and symbol used in paper)		To convert from	to	multiply by
Length	x	inch	meter	$2.54^* \times 10^{-2}$
		foot	m	$3.048^* \times 10^{-1}$
Area		inch ²	m ²	6.4516×10^{-4}
		foot ²	m ²	9.290×10^{-2}
Volume		inch ³	m ³	1.639×10^{-5}
		foot ³	m ³	2.832×10^{-2}
Temperature		Fahrenheit	Celsius	$t_C = (t_F - 32)/1.8$
Temperature difference		Fahrenheit	Kelvin	$K = (\Delta t_F)/1.8$
Pressure		inch Hg (60°F)	newton/m ²	3.377×10^2
Mass		lbm	kg	4.536×10^{-1}
Mass/unit area	M	lbm/ft ²	kg/m ²	4.882
Moisture content rate		lbm/ft ² week	kg/m ² s	8.073×10^{-6}
Density	'	lbm/ft ²	kg/m ²	1.602×10^1
Thermal conductivity	k	Btu/hr ft ² (F/inch)	$\frac{W}{mK}$	1.442×10^{-1}
U-value		Btu/hrft ² °F	$\frac{W}{m^2K}$	5.678
Thermal resistance	R	F/(Btu/hr ft ²)	K/(W/m ²)	1.761×10^{-1}
Heat flow		Btu/hr ft ²	W/m ²	3.155
Water vapor: permeability	p	grain hr ft ² (in.Hg/in.)	kgm/Na	1.457×10^{-12}
permeance	p,P	grain hr ft ² (in.Hg) (perm)	kg/Na	5.738×10^{-11}

* Exact value; others are rounded to fourth place.

1.0 INTRODUCTION

As part of its response to the energy crisis, the General Services Administration (GSA), in 1972, designated the proposed Federal Office Building in Manchester, New Hampshire, as an energy conservation demonstration project to evaluate energy conservation techniques in the design and operation of a contemporary office building.

The GSA subsequently appointed a design team to incorporate energy conservation techniques in the building. This team consisted of the GSA project administrator and staff from the Central and Region I Offices; Dubin Bloome Associates, Energy Conservation Consultants; Isaak and Isaak, Architects; Rose, Goldberg and Associates, Structural Consultants; Richard D. Kimball Co., Mechanical Consultants; and the National Bureau of Standards (NBS), design and evaluation consultants.

With the aid of the computerized National Bureau of Standards Load Determination Programs (NBSLD)¹, the effects of various building design alternatives on the annual energy consumption of the proposed building were evaluated by NBS. The NBS also assisted the Mechanical Consultant in sizing various components of the heating ventilation and air conditioning HVAC systems. Furthermore, the NBS drafted specifications to purchase a computerized energy monitoring and control system to measure the energy consumption and performance data.

In brief, the design team selected for the proposed Federal building the following opportunities for energy conservation: building envelope design including doors, windows, mass and insulation; various designs; solar energy for space heating and cooling; and various lighting systems.² Construction of the building began in December 1974 and was completed in August 1976. Fifteen Federal agencies serving the region now occupy the building, which has subsequently been designated as the Norris Cotton Federal Office Building.

In addition to its role in the building design and energy monitoring, NBS was also requested by the then Energy Research and Development

¹ Tamami Kusuda, James E. Hill, Stanley T. Liu, James P. Barnett and John W. Bean, Pre-Design Analysis of Energy Conservation Options for a Multi-Story Demonstration Office Building, U.S. Department of Commerce, National Bureau of Standards, Building Science Series 78,

² For a detailed description of the specific energy conservation features selected for the building, see Nicholas Isaak and Andrew Isaak, Designing an Energy-Efficient Building: A Case Study, General Services Administration, September 1975.
November 1975.

Administration (ERDA) and now the Department of Energy (DOE) to make post-occupancy evaluations on the economic, engineering and user acceptance aspects of the energy conservation techniques. This report is written to fulfill the requirement of an economic evaluation after the building is occupied.

1.1 PURPOSE

The purpose of this report is to present the results of an analysis of the cost effectiveness of the investments made in the energy conserving techniques for the Norris Cotton Federal Office Building in Manchester, N.H. This analysis addressed the question of whether the additional construction costs incurred in order to reduce the energy consumption of the building are adequately offset by the value of the resulting annual energy savings.

1.2 SCOPE AND APPROACH

In this report, the construction costs of the Norris Cotton Federal Office Building (NCFOB) and an Equivalent Conventional Building (ECB) are combined with the corresponding annual energy consumption in a present value format of a maximum lifespan of 40 years. The ECB was designed in such a way that its size and shape, quality of material and construction, and occupancy requirements would be approximately equal to those of the NCFOB. The life-cycle costs resulting from initial construction and annual energy use are calculated for both buildings and serve as the basis of the economic evaluation.

Since the computerized energy monitoring and control system did not become operational until December 1977, detailed energy consumption and corresponding operating efficiencies of the individual energy conserving features could not be measured at this time. Therefore, only the monthly energy consumption data as reported by the utility companies for the past year are used in conjunction with the actual construction cost of NCFOB to present the life-cycle cost of the building as a whole. In accordance with the GSA Design Handbook of 1969, the building costs and yearly energy consumption for the ECB are estimated. These estimates are compared and validated with data compiled by GSA.

For the past year, the NCFOB has been operated and maintained by GSA personnel as well as the construction contractors who have been, from time to time, correcting the defects and furnishing the omissions in the building. Therefore, no meaningful data on the non-energy operation and maintenance are accurate enough to be included in the economic analysis at this time. This report includes only the total building construction costs and yearly energy costs of the NCFOB and ECB in the economic evaluation. Economic evaluations involving other variables are suggested in Section 4.0 as future research efforts.

1.3 ORGANIZATION

The remainder of this report is divided into the following sections and appendices.

Section 2.0 describes the physical attributes, the costing method and construction costs for both the NCFOB and ECB. The methods of calculating annual energy consumption for both the NCFOB and ECB are also described.

Section 3.0 contains the economic evaluation of both NCFOB and ECB. A life-cycle cost model is developed here using present worth analysis of the building investment cost and energy cost for a lifespan of up to 40 years. This model is used to obtain the present values of both NCFOB and ECB costs, based on (reasonable) upper and lower limits of energy use, energy price increases and lifespans.

Section 4.0 summarizes the findings of the economic analysis for the NCFOB. Recommendations are made for conducting further research such as the inclusion of operation and maintenance costs in the life-cycle model and performing economic analyses of those individual energy-conserving features which permit independent evaluation.

The appendices include the detailed listings of all construction cost, energy usage and price data and the year-to-year present value costs for both the NCFOB and ECB.

2.0 CONSTRUCTION COST AND ENERGY CONSUMPTION

Two kinds of data, namely construction cost and energy consumption, are developed in this section. Preceding the development of construction cost and energy consumption data, the selection of the ECB suitable for the economic comparison is required. The procedure for choosing a design for the ECB is as follows.

2.1 ECB SELECTION

A brief description of the NCFOB is needed in order to understand how the ECB is selected.

2.1.1 NCFOB Description

The NCFOB was designed and constructed with two levels for underground parking, seven office floors, and a mechanical house. The typical office floor is 130 feet x 110 feet in size. The entire building has an area of approximately 176,000 gross square feet.

In order to reduce heat loss through the exterior surfaces, the building is shaped like a cube from the second through the seventh floors. First floor area is extended beyond the general cube to provide for additional ground floor space. The exterior surfaces are more massive than that of conventional buildings. There is also less window area and thicker insulation provided for the exterior surfaces in this building. Energy conserving mechanical and electrical systems are provided in the building. Part of Appendix A is devoted to presenting more specific details of the design requirements for the NCFOB.

2.1.2 ECB Design Requirements

In 1976, the architectural consulting firm of Isaak and Isaak in Manchester, New Hampshire, was contracted by the NBS to develop a comparable design and corresponding construction cost for the ECB. Issak and Isaak had done an early version of the NCFOB. Following is a list of general criteria used for the selection of the ECB design.

1. That the total assignable area be identical to that in the NCFOB.
2. That the auxiliary spaces such as parking and maintenance work spaces be of the same size as the NCFOB.
3. That the construction site be the same as the NCFOB.
4. That the conventional design be in compliance with GSA Design Handbooks and acceptable local practices.
5. That the architectural and engineering quality be the same as the NCFOB.
6. That the period of construction be the same as the NCFOB, from May 1, 1974 to August 24, 1976.

A design for the ECB was selected by Isaak and Isaak and accepted by the NBS. The specific design requirements are described in Appendix A.

2.2 BUILDING CONSTRUCTION COSTS

The construction costs developed here for the NCFOB and ECB do not include the following cost items: Site acquisition cost; architecture and engineering design fees¹; furniture and furnishing cost; and relocation cost. These cost items are excluded from the economic comparison because they are generally considered to be equal for both buildings and therefore will not affect the outcome of the cost comparison of both buildings. The construction costs are described as follows.

The NCFOB construction cost represents the original contract price in the Spring of 1974 to be fully paid for in the Fall of 1976. All contract change orders made during the construction period were adjusted so that the resulting figures represent the dollar values as of the start of construction. The sum of the original contract price and the adjusted change order prices is used here as the total NCFOB construction cost incurred at the end of 1976.

The ECB construction cost developed here was originally estimated by Isaak and Isaak and subsequently modified by the NBS and reviewed by the GSA. A major modification is the change from a six story building to a seven story building to provide the same height for both buildings.

Based on the cost data contained in Appendix A, the resulting information suitable for the economic evaluation is shown in Table 2.1.

2.3 ANNUAL ENERGY CONSUMPTION

Two distinct estimates of the annual energy consumption for each of the two buildings were made. The detailed data on which these estimates were made can be found in Appendix B.

2.3.1 Energy Consumption for NCFOB

For the NCFOB the predicted level of energy consumption shown in Table 2.2 was computed by the NBSLD program using 1962 weather data.²

¹ The design fees for the NCFOB are considerably larger than those for the ECB at this time. It is expected, however, that by sharing design methods in professional publications, the design fees for energy conservation buildings eventually will be equal to those for the conventional buildings.

² The monthly average temperatures for 1962 were very close to the thirty year norm values for Manchester, N.H. See Tamami Kusuda, James E. Hill, Stanley T. Liu, James P. Barnett and John W. Bean, Pre-Design Analysis of Energy Conservation Options for a Multi-story Demonstration Office Building, U.S. Department of Commerce, National Bureau of Standards, Building Science Series 78, November 1975.

Table 2.1

Building Construction Costs in 1976 Dollars

Building Elements	Buildings	
	NCFOB	ECB
Architectural/Structural	\$6,147,122	\$5,706,361
Mechanical	1,195,731	944,028
Electrical	<u>576,181</u>	<u>698,698</u>
Subtotal	7,919,034	7,349,087
GC Overhead/Profit	<u>601,847</u>	<u>558,531</u>
TOTAL	8,520,881	7,907,620
Less Extras For Non-building Items ^a	<u>-285,765</u>	<u>None</u>
Comparable Cost	\$8,235,116	\$7,907,620

^a This figure represents the "Demonstration" items as explained in Appendix A.

Table 2.2

Annual Energy Consumption for NCFOB in 10^9 BTU and 1977 Dollars

Energy Type	Predicted Level for 1962 Weather Data		Actual Level for 1977	
	10^9 BTU	1977 Dollars ^a	10^9 BTU	1977 Dollars ^a
Natural gas	2.290	\$13,900	2.421	\$14,695
Fuel oil	0	0	0.801	2,339
Electricity	<u>3.886</u>	<u>40,298</u>	<u>5.465</u>	<u>56,672</u>
TOTAL	6.176	\$54,198	8.687	\$73,706

^a See Appendix B for detailed energy consumption data and prices for various energy types.

The actual level of energy consumption was calculated from the monthly utility bills actually paid in 1977.

The actual energy usage in 1977 is 40.7 percent higher than the predicted level for 1962. This 40.7 percent increase may be traced to the difference in weather conditions between 1962 and 1977, the requirement for equipment shake-down operations during the first year of occupancy and other non-weather factors which might include the effective insulation value and infiltration value of the building envelop and the operating efficiency of this building equipment.

While the actual energy usage in 1977 is 40.7 percent higher than the predicted level in 1962, the dollar value of the actual energy use in 1977 is 36 percent more than the predicted level in 1962. This apparent discrepancy between 36 and 40.7 percent is caused by the fact that in 1977, about 9 percent of the total energy used was supplied by fuel oil, the unit price of which (cost per million BTU) is less than one half of that for the natural gas. Consequently this unit price differential between fuel oil and natural gas reduces the effective increase from 40.7 to 36 percent.

2.3.2 Energy Consumption for ECB

For the ECB the predicted level of energy consumption shown in Table 2.3 was computed by the NBSLD program using 1962 weather data. To correct for the difference in weather conditions between 1977 and 1962, the adjusted level of energy consumption is shown in Table 2.3 to reflect a 10 percent increase¹ of energy consumption from the predicted level.

The annual energy costs are assumed to accrue at the end of the year. The construction cost and building energy consumption data in this section will be used for the economic evaluation presented in Section 3.0.

¹ A 10 percent increase of energy consumption was selected because of the effect of the 8209 degree-days recorded for 1977 over the 7586 degree-days recorded for 1962. This increase of degree-days is equivalent to a 10% increase in energy use based on the average response of similar buildings studied by the Building Owners and Managers Association (BOMA) for 91 conventional office buildings.

Table 2.3

Annual Energy Consumption for ECB in 10^9 BTU and Dollars

Energy Type	Predicted Level for 1962 Weather Data		Adjusted Level for 1977	
	10^9 BTU	1977 Dollars ^a	10^9 BTU	1977 Dollars ^a
Natural Gas	4.983	\$ 30,247	5.481	\$ 33,270
Fuel Oil	0	0	0 ^b	0 ^b
Electricity	<u>7.277</u>	<u>75,462</u>	<u>8.005</u>	<u>83,012</u>
TOTAL	12.260	\$105,709	13.486	\$116,281

^a See Appendix B for detailed energy consumption data and prices for various energy types.

^b Since fuel oil is the standby energy type for heating and is intended to be used intermittently and without any planned frequency, the annual fuel oil consumption for the adjusted level in 1977 is assumed to be zero. This assumption tends to increase the total dollar value of the energy consumption for ECB when comparing with the actual level for NCFOB in 1977 listed in Table 2.2.

3.0 ECONOMIC EVALUATION

The comparable building cost and energy consumption data presented in the preceding section will be combined here to form the building life-cycle costs for owning and operating the NCFOB and ECB. These building life-cycle costs will be used for the economic evaluation.

3.1 LIFE-CYCLE COST MODEL

There are several methods to express the combined cost of an initial investment and associated recurring costs of energy consumption, operation, and maintenance of a building. One method is to transform the initial investment cost into an equivalent yearly uniform capital recovery payment over the life and then combine this yearly payment with the corresponding recurring costs associated with operation, maintenance and energy consumption over the life of the building. Another method is to transform both the initial building investment cost and the recurring costs to a single capital recovery amount occurring at the end of the lifespan. The third method is to bring the stream of recurring costs back to the same period in which the initial building investment was made and then combine these transformed recurring costs with the initial investment to arrive at the present value cost of owning and operating a building throughout its life. This present value cost method will be used for the economic evaluation of both buildings. Formula 3.1 is the general expression used to obtain present value costs over a building lifetime.

$$PVC = C + \sum_{i=1}^L (1+D)^{-i}(E_i+M_i) - (1+D)^{-L} \cdot S \quad , \quad (3.1)$$

where

- PVC = Present value cost
- C = Construction cost
- D = Discount rate
- E_i = Annual energy cost in period i
- M_i = Annual operation and maintenance cost (excluding energy cost)
- L = Lifespan of the building in years
- S = Salvage value at the end of lifespan

For the first 12 months since the completion of the building, both the building contractors and the GSA personnel have been jointly responsible for the building operation including the start-up and the adjustment of building equipment. With the exception of energy cost, no meaningful physical and cost data for building operation and maintenance have yet been collected.¹ Until such meaningful operation and maintenance data

¹ Generally, the building contractors will correct the defects in construction and adjust the building equipment to comply with the original design during the warranty period.

become available, it is not unreasonable to assume that these costs would be approximately equal for both buildings.

Similarly, for practical purposes the salvage values for the NCFOB and ECB are considered equal and negligible, given the relatively long expected life of a building. Therefore, Formula 3.1 can be simplified to

$$PVC = C + \sum_{i=1}^L (1+D)^{-i} \cdot E_i \quad (3.2)$$

Formula 3.2 will be used for the economic evaluation in this report.

3.2 DATA ASSUMPTIONS

Derived in the previous section, the specific data used here for calculations are the building construction costs shown in Table 2.1 and the annual energy consumption listed in Tables 2.2 and 2.3.

In order to obtain estimates of the annual energy price increases for Manchester, New Hampshire, the Environment and Energy Branch in the Central Office of GSA was consulted.¹ The GSA energy price increases for the next 40 years depicted in Table 3.1 are the product of this consultation. Also, the energy price increases in the New England Region as forecasted by the Federal Energy Administration² are shown as the FEA price increases in Table 3.1.

The discount rate, D, required for the calculation in Formula 3.2, is 10 percent throughout the economic evaluation in compliance with OMB Circular No. A-94, Revised, March 27, 1972.

3.3 ECONOMIC COMPARISON

Based on the construction costs listed in Table 2.1, energy consumption data listed in Tables 2.2 and 2.3, annual energy price increases listed in Table 3.1 and the discount rate of 10 percent, present value costs are calculated with Formula 3.2. The results for the NCFOB and the ECB are shown in Table 3.2.

The present value of savings listed in Table 3.2 are the differences between the present value cost of the ECB and the NCFOB. The range of present value savings represents the cost effectiveness of the energy conservation investment made in the NCFOB, when measured with the actual (or adjusted) and predicted energy consumption levels and the GSA and FEA energy price increases.

¹ G. Wells, Chief of the Environment & Energy Branch, Public Building Series, GSA, was particularly helpful in this regard.

² "Energy Audit Procedure: Proposed Rules and Hearing," Federal Register, Vol. 42, No. 73, April 15, 1977.

Table 3.1

Estimated Annual Percentage Increases in Real Energy Prices

Period	Type of Energy	Annual Energy Price Increase (%)	
		Probable ^a	Low ^b
1978 through 1980	Natural gas	16	3.62
	Fuel oil	8	1.20
	Electricity	16	0.38
1981 through 1990	Natural gas	6	3.62
	Fuel oil	4	1.20
	Electricity	6	0.38
1991 through 2016	Natural gas	6	0
	Fuel oil	4	0
	Electricity	6	0

^a Estimates of the GSA Environmental and Energy Branch for the Manchester, N.H. area.

^b Estimates for the New England Region, published by FEA, "Energy Audit Procedure, Proposed Rules and Hearing," Federal Register Vol. 42, No. 73, April 15, 1977.

Table 3.2

Present Value Costs and Calculation of Present Value Savings (\$1000)

		Lifespan and energy price increase			
		40 year		20 year	
		GSA Energy Price Increase	FEA Energy Price Increase	GSA Energy Price Increase	FGA Energy Price Increase
Adjusted or actual	ECB	\$10,787	\$9,165	\$9,836	\$8,988
Energy Consumption 1977	NCFOB Saving ^a	10,059 728	9,021 144	9,457 379	8,911 77
Predicted	ECB	10,524	9,050	9,660	8,889
Energy Consumption 1962	NCFOB Saving ^a	9,577 947	8,816 234	9,134 526	8,735 154

^a Present value savings of the NCFOB over the ECB for the given lifetime.

Several noteworthy conclusions can be drawn from an examination of Table 3.2. Most importantly, the present value savings under all sets of assumptions are positive. These positive present value savings indicate that the additional investment in energy conservation in the NCFOB is more than compensated by the value of the energy savings over the 40 year and 20 year lifespans assumed. In other words, the NCFOB is economically more attractive than the ECB for all cases studied.

Another result is that the present value savings under all four cases assuming adjusted and actual (1977) energy consumptions are lower in value than the corresponding savings calculated for the predicted (1962) in energy consumptions. This anomaly has arisen because the values of the 1977 energy consumption for the ECB and NCFOB do not represent an equal percentage increase over the corresponding 1962 consumption values. As stated in Section 2.0, the dollar value of the actual energy used in the NCFOB was 36 percent greater than that of the consumption calculated for the 1962 base year while the 1977 energy consumption estimated for the ECB is only 10 percent more than that of the 1962 base year when weather differences only are taken into account. One way to eliminate this anomaly is to increase the estimated 1977 energy expenditures for the ECB to 36 percent above that which was calculated by the NBSLD for the 1962 base year. The results of this modification are presented in Table 3.3.

A comparison of Table 3.3 with Table 3.2 reveals that the modification of the energy consumption for ECB makes the present value savings greater for the actual energy consumption case than for the low consumption case, as one would expect.

Another important result in Table 3.2 is that the present value savings rendered by the NCFOB are \$947,000 in 40 years and \$526,000 in 20 years under the most probable set of assumptions. These assumptions seem to be the most reasonable because the 1962 weather data year is a more representative one to base the life-cycle cost analysis on than that of 1977.¹ Furthermore, the computer analysis performed for both the NCFOB and ECB with 1962 weather data are based on the same assumptions included in the NBSLD calculations. In contrast, the 1977 analysis is based on the actual energy consumption for the NCFOB but is forced to depend on the computer calculations of energy consumption for the ECB.

Table 3.2 also indicates that for a 40 year lifespan, there is a low present value saving of \$234,000 for the FEA energy price increases and a high present value saving of \$947,000 for the GSA energy price increases. This result fulfills the expectation that for this NCFOB, the present value saving becomes larger, the faster energy prices rise. Also as expected, Table 3.2 indicates that for the NCFOB, the longer the lifespan chosen for evaluation, the bigger the present value saving accumulated over that life.

¹ As noted above the monthly average temperatures in 1962 were very close to thirty year norm values for Manchester, N.H.

Table 3.3

Present Value Costs and Savings with Modified
Energy Consumption for ECB (\$1000)

	Lifespan and energy price increase			
	40 year		20 year	
	GSA Energy Price Increase	FEA Energy Price Increase	GSA Energy Price Increase	FEA Energy Price Increase
ECB ^a	\$11,466	\$9,462	\$10,291	\$9,243
NCFOB	10,059	9,021	9,457	8,911
Saving ^b	1,407	441	834	332

^a Present value costs for ECB assuming energy consumption 36 percent greater than estimated for the 1962 base year.


^b Present value savings of the NCFOB over the ECB for the given lifetime.

In addition to the present value saving, it is possible to calculate the discounted payback period for the additional investment made on the energy conserving features of the NCFOB. The discounted payback period is defined as the number of years required for the additional investment in a building to be fully paid for with the present value savings produced by the energy conservation features, taking into account the time value of money.¹ The discounted payback periods, 6.4 years, 9.7 years, 7.8 years and 12.8 years, are shown in Figures 3.1 through 3.4 for the energy conservation investment made in the NCFOB compared with the ECB under the four sets of assumptions concerning the level of energy consumption and energy price increases. The present value savings of the NCFOB over the ECB for all given lifetimes of up to 40 years can also be determined by measuring the distance between the two curves shown on each of the four figures.

¹ The discounted payback for this type of economic analysis is calculated by finding that lifespan for which the present value costs of the NCFOB and the ECB are equal. See Appendix C for the listing of present value costs for each building for all lifespans from 1 through 40 years.

Figure 3.1


Case I - Present Value Cost^a vs Lifespan for NCFOB and ECB



^a Case I - Present value cost is assumed to include the building construction cost, energy cost as computed for 1962 consumption and GSA estimates for annual energy price increase.

Figure 3.2


Case II - Present Value Cost^a vs Lifespan for NCFOB and ECB



^a Case II - Present value cost is assumed to include the building construction cost, energy cost as computed for 1977 consumption and GSA estimates for annual energy price increase.

Figure 3.3


Case III - Present Value Cost^a vs Lifespan for NCFOB and ECB



^a Case III - Present value cost is assumed to include the building construction cost, energy cost as computed for 1962 consumption and FEA estimates for annual energy price increase.

Figure 3.4

Case IV - Present Value Cost^a vs Lifespan for NCFOB and ECB



^a Case IV - Present value cost is assumed to include the building construction cost, energy cost as computed for 1977 consumption and FEA estimates for annual energy price increase.

4.0 SUMMARY AND RECOMMENDATIONS FOR FURTHER RESEARCH

As a result of this economic evaluation, a brief summary and several recommendations for further research can be offered.

4.1 SUMMARY

1. It cost \$327,000 more to build the NCFOB than the ECB. This additional cost amounts to 4.1 percent of the ECB construction cost estimated to be \$7,908,000. Once the design and construction methods suitable for energy conservation become more widely known and practiced, the additional cost of constructing such an energy conserving building as compared to a conventional building might be even less.
2. Depending on the assumptions made concerning the levels of energy consumption, the rates of energy price increase, and the useful lifespans, the present value savings of investing in the energy conserving features in the NCFOB are all positive and range from a low of \$77,000 to a high of \$1,407,000. Based on the most probable set of assumptions, the present value savings measured in 1976 dollars are \$947,000 for a 40 year lifespan and \$526,000 for a 20 year lifespan.
3. Depending on the assumptions made concerning the levels of energy consumption and the rates of energy price increase, the discounted payback periods range from a low of 6.4 years to a high of 12.8 years. Under the most probable set of assumptions, the discounted payback period for the additional investment (\$327,000) made in the NCFOB is 6.4 years.
4. The actual energy cost, based on the utility bills paid for the NCFOB in 1977, is 36 percent more than the computed energy cost based on the NBSLD calculation for 1962 weather conditions. Of this increase, only a small percentage can be attributed to the change in weather conditions. The bulk of the increase cannot be properly explained until the detailed thermal engineering analysis, currently underway for the building and equipment, has been completed.

4.2 RECOMMENDATIONS FOR FURTHER RESEARCH

1. I recommend that a study be made on the cost-effective use of the four gas-fired and two standby oil-fired boilers provided in the NCFOB. This study should consider the energy cost, operating efficiency and maintenance cost for the cost-effective use of the two types of boilers. Under present operating condition, the oil-fired boilers have been used intermittently and sparingly in January, February, July, August, September and December of 1977. In view of the current cheaper energy price for fuel oil as compared to that for natural gas, it appears to be more cost effective at this time to run the oil-fired boiler more often. However, other factors such as the operating efficiency and maintenance cost should be included in a study involving the cost-effective use of the two types of boiler.

2. I recommend that an economic evaluation be made of various individual energy conserving features such as the alternative lighting systems, the engine generators, and the heat pumps. The results of this economic evaluation would help building designers, owners and operating personnel to select cost-effective investments for energy conservation in buildings. We anticipate that detailed energy consumption data for individual energy conserving features will be measured and monitored by the new computerized energy monitoring and control system (JC-80), and that these data will be available for evaluation by the Fall of 1978.

3. I recommend that a more comprehensive economic evaluation be made on the NCFOB. This economic evaluation should not only incorporate cost data on building operation and maintenance, but also the revised energy consumption data to be derived from the on-going thermal engineering analysis.

Appendix A

BUILDING DESIGN AND COST DATA

The following design and cost data have had been extracted from an unpublished report, Nicholas Isaak and Andrew Isaak Comparative Cost Study As Built vs. Equivalent Conventional Buildings, October 1975. This report was funded and monitored by the NBS as Contract No. T73183 -- Request No. 463-3269. These data are divided into three major categories: (1) Design Criteria Comparison; (2) Building Cost Comparison; and (3) Demonstration Items.

A.1 DESIGN CRITERIA COMPARISON

Both NCFOB and ECB are reinforced concrete structures of seven stories. A comparison of the major design requirements or features¹ are presented in the following three tables.

With the exception of the underground garage and mechanical and electric service areas, all spaces are provided with HBAC. The design requirements of the HVAC. The design requirements of the HVAC systems are listed in Table A.2.

Lighting and power design requirements for the buildings are listed in Table A.3.

A.2 BUILDING CONSTRUCTION COST COMPARISON

Itemized NCFOB construction costs and the corresponding ECB construction estimates are listed in Table A.4 below in the Construction Specification Institute (CSI) format. The costs include the total construction costs but exclude site acquisition costs and building design fees.

¹ For a full description of the NCFOB, see Nicholas Isaak and Andrew Isaak, Designing an Energy Efficient Building, A Case Study, (General Services Administration, September 1975.)

TABLE A.1

Building Structure and Envelope Design Requirements

Element	Building	
	NCFOB	ECB
Roof	U = 0.06, insulation is placed on the exterior side of a 8" thick concrete roof.	U = 0.15, minimum insulation is placed on a 4" thick concrete roof.
Wall	U = 0.06, 3 3/4" insulation is placed on the exterior side of the 12" thick block wall; granite exterior facing.	U = 0.16, 1" insulation is placed on a 6" thick block wall; granite exterior facing.
Window	U = 0.55, window area is 5% of wall area. Thermally broken double glazed with built in venetian blinds.	U = 1.13, window area is 40% of wall area, 1/4" plate glass, single glazed.

Table A.2
HVAC Design Requirements

Requirements	Building	
	NCFOB	ECB
Winter outdoor design temperature	(+) 5°F	(-) 10°F
Winter indoor design temperature	(+) 68°F	(+) 75°F
Summer outdoor design conditions	86°F. DB, 73°F. WB	90°F. DB, 73°F. WB
Summer indoor design conditions	78°F. DB, 60% R.H.	75°F. DB, 50% R.H.
Outside air ventilation	6 CFM per person (generally .06 CFM per square foot of floor)	0.25 CFM per square foot of floor
"U" Walls	0.06 BTU/S.F./°F	0.16 BTU/S.F./°F
"U" Roof	0.06 BTU/S.F./°F	0.15 BTU/S.F./°F
"U" Glass	0.55 BTU/S.F./°F	1.13 BTU/S.F./°F
Shading	Building structure designed to be 80 to 100% efficient in prohibiting summer solar load and 80 to 90% efficient in permitting winter solar.	No special provisions venetian blinds for summer solar reduction

TABLE A.3
Electrical Design Requirements

Spaces	Building	
	NCFOB	ECB
Office Space	Lighting = 2W/sq. ft. avg.	Lighting = 6W/sq. ft. max.
Storage (Potential Office)	Lighting = 2W/sq. ft. avg.	Lighting = 6W/sq. ft. max.
Lobbies	Lighting = 2.5W/sq. ft.	Lighting = 4W/sq. ft.
Toilet Storage & Utilities	Lighting = 1W/sq. ft.	Lighting = 3W/sq. ft.
Permanent Corridor	(None)	Lighting = 2W/sq. ft.
Parking	1/2 fc average	Lighting = 5 fc storage, 10 fc traffic
Office Receptacles	1W/sq. ft.	1W/sq. ft.

A.3 DEMONSTRATION ITEMS

Following are specific items installed in the NCFOB strictly for special experiments or measurements which are not normally required for the operation of the ECB. Specific item numbers refer to A.4. The negative value of the cost differential indicates that the specific item for the NCFOB costs more than that for the ECB.

Table A.4

Building Construction Cost Comparison

ITEM	NCFOB			ECB		
	QUANTITY	UNIT COST(\$)	TOTAL COST(\$)	QUANTITY	UNIT COST(\$)	TOTAL COST(S)
DIV. 1 GENERAL						
1.1 Temporary facilities			181280			274000
1.2 G.C. equipment			288000	same		288000
1.3 Clean up			30000	same		30000
1.4 Field Engineering			15000	same		15000
1.5 Field Offices & Shed	3 each	5000	15000	same		15000
1.6 Field overhead						
a. Superintendent	125 wk.	300	37500	same		37500
b. Field engineer	60 wk.	250	15000	same		15000
c. Clerk	100 wk.	200	<u>20000</u>	same		<u>20000</u>
DIV. 1 TOTAL			601780			694500
DIV. 2 SITE WORK						
2.1 Earth work						
a. Building excavation	39000 c.y.	2.39	93060	same		93060
b. Fill & backfill	3000 c.y.	1.62	4860	same		4860
2.2 Pile Foundations						
a. Shoring & shor removal	18340 s.f.	9.87	181050	same		181050
b. Steel piles	8422 l.f.	14.31	120526	8000 l.f.	14.31	114480
c. Pile caps	1600 c.y.	34.53	55250	same		55250
d. Rock bolts	1600 l.f.	45.58	72930	same		72930
2.3 Dewatering	15 mo.	3111	46665	same		46665

Table A.4 Continued

ITEM	NCFOB			ECB		
	QUANTITY	UNIT COST(\$)	TOTAL COST(\$)	QUANTITY	UNIT COST(\$)	TOTAL COST(\$)
2.4 Site utilities			11475	same		11475
2.5 Landscaping			<u>12920</u>	same		<u>12920</u>
DIV. 2 TOTAL			598736			592690
DIV. 3 CONCRETE						
3.1 Cast in place concrete						
a. Sub grade walls	682 c.y.	228	155462	same		155462
b. Sub basement slab	1782 c.y.	150	267444	same		267444
c. Basement slab & beams	1344 c.y.	208	273700	same		273700
d. Columns below grade	130 c.y.	120	15640	120 c.y.	120	14400
e. Gr. level slab & beams	1936 c.y.	166	320620	1730 c.y.	166	290320
f. Concrete fireproofing	170 c.y.	138	23460	240 c.y.	138	33120
g. Roof slab & penthouse	635 c.y.	160	101660	276 c.y.	160	44160
h. Concrete topping	351 c.y.	111	39100	same		39100
i. Planters & ret. walls	2885 c.y.	5.42	15640	same		15640
j. Slab on metal floor deck	1027 c.y.	214	220363	1167 c.y.	214	249738
k. Spandrels above window	none			358 c.y.	250	64500
3.2 Precast concrete	6120 s.f.	6.02	<u>36860</u>	4658 s.f.	6.02	<u>27948</u>
DIV. 3 TOTAL			1469949			1475532
DIV. 4 MASONRY						
4.1 Concrete unit masonry						
a. Exterior 12 inch	37000 s.f.			none		
8 inch	3070 s.f.	3.63	145350	750 s.f.	3.20	33312
6 inch	none			9660 s.f.		

Table A.4 Continued

ITEM	NCFOB			ECB		
	QUANTITY	UNIT COST(\$)	TOTAL COST(\$)	QUANTITY	UNIT COST(\$)	TOTAL COST(\$)
b. Interior 12 inch	360 s.f.			none		
8 inch	37400 s.f.	2.78	108612	37400 s.f.	2.78	112423
6 inch	600 s.f.			none		
4 inch	750 s.f.			3040 s.f.		
4.2 Cut Stone						
a. Building facing	54968 s.f.	9.27	509553	40584 s.f.	9.27	376214
b. Plaza paving						
exterior	6900 s.f.	6.00	54600	same		54600
interior	2200 s.f.			2200 s.f.		
DIV. 4 TOTAL			818115			576549
DIV. 5 METALS						
5.1 Structural steel	966 ton	855	851262	810 ton	800	648800
5.2 Misc. metals						
a. Support brackets	54968 s.f.	2.59	142367	40584 s.f.	2.25	91314
b. Steel stairs	405 riser	75.44	30555	same		30555
c. Gratings			4365	same		4365
d. Handrails ground	480 l.f.	14.23	6832	same		6832
e. Miscellaneous			42750	same		42750
5.3 Metal deck (all)	84076 s.f.	2.19	184300	118050 s.f.	2.19	258530
5.4 Architectural metal						
exhibit case, seals			5985	same		5985
DIV. 5 TOTAL			1268416			1089131

Table A.4 Continued

ITEM	NCFOB			ECB		
	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)
DIV. 6 WOOD & PLASTIC						
6.1 Rough carpentry			13847	same		13847
6.2 Finish carpentry			<u>15826</u>	same		<u>15826</u>
DIV. 6 total			29673			29673
DIV. 7 THERMAL & MOISTURE PROTECTION						
7.1 Waterproofing						
a. Below grade	51740 s.f.	1.78	92150	same		92150
b. Above grade	37653 s.f.	1.12	41994	same		41994
7.2 Building insulation						
a. Interior	69230 s.f.	.13	8730	same		8730
b. Exterior	54968 s.f.	.39	21438	42438 s.f.	.20	8488
7.3 Insl. metal panel	13817 s.f.	9.54	131860	240 s.f.	4.00	960
7.4 Roofing system	206 s.f.	190	39200	208 sq.	130	27040
7.5 Sheetmetal & flashing			37829			28372
7.6 Sealants			<u>26220</u>			<u>19665</u>
DIV. 7 total			399421			227399
DIV. 8 DOORS & WINDOWS						
8.1 Hollow metal frames	225 each	34.46	7754	265 each	34.46	9132
8.2 Doors	305 each	91.67	27955	same		27955

Table A.4 Continued

ITEM	NCFOB			ECB		
	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)
8.3 Aluminum work	2054 s.f.	18.58	38160	2200 s.f.	18.58	40876
8.4 Special doors	2 each	3000	<u>17164</u>	same		<u>6000</u>
DIV. 8 total			216718			264751
DIV. 9 FINISHES						
9.1 Gypsum drywall						
a. Column fireproofing	7781 s.f.	4.01	31227	10320 s.f.	4.01	41383
b. Partitions	24543 s.f.	1.18	28889	46500 s.f.	1.18	54870
c. Wall furring	8390 s.f.	.58	4867	19300 s.f.	.58	11194
9.2 Tile work						
a. Ceramic tile	8350 s.f.	1.70	14191	same		14191
b. Quarry tile	1000 s.f.	4.24	4239	same		4239
9.3 Acoustical ceiling	93900 s.f.	1.15	108300	91900 s.f.	.74	68006
9.4 Resilient flooring						
a. Vinyl asbestos flooring	15500 s.f.	.48	7421	same		7421
b. Stair treads	405 ea.	8.28	3353	same		3353
9.5 Carpeting	7550 s.y.	8.30	62662	same		62662
9.6 Cementitious coating	14935 s.f.	.79	11733	same		11733
9.7 Spray fire protection	84078 s.f.	.43	36100	118050 s.f.	.43	50762
9.8 Painting & finishing			37001	same		37001
9.9 Vinyl wall covering			<u>1890</u>	same		<u>1890</u>
DIV. 9 total			351883			368705

Table A.4 Continued

ITEM	NCFOB			ECB		
	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)
DIV. 10 SPECIALTIES						
10.1 Toilet partitions			7581	same		7581
10.2 Access flooring			5000	none		
10.3 Flag pole	1 ea.	2708	2708	same		2708
10.4 Mail chute	94 l.f.	29.41	2765	same		2765
10.5 Folding partitions	1167 s.f.	8.00	9336	same		9336
10.5 Relocatable partitions	22360 s.f.	2.74	61370	same		61370
10.7 Toilet room accessories			7526	same		7526
10.8 Misc. specialties			<u>13088</u>	same		<u>13088</u>
DIV. 10 total			109374			104374
DIV. 11 EQUIPMENT						
DIV. 12 FURNISHINGS						
DIV. 13 SPECIAL CONSTRUCTION						
13.1 Radiation protection			<u>5990</u>	same		<u>5990</u>
DIV. 13 total			5990			5990

Table A.4 Continued

ITEM	NCFOB			ECB		
	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)
DIV. 14 CONVEYING SYSTEMS						
14.1 Dumbwaiters	1 ea.	7220	7220	same		7220
14.2 Elevators						
a. Freight	10 stops	1 ea.	91748	same		91748
b. Passenger	9 stops	2 ea.	<u>178099</u>	same		<u>178099</u>
DIV. 14 total			<u>277067</u>			<u>277067</u>
TOTAL OF ARCHITECTURAL & STRUCTURAL			6147122			5706361
DIV. 15 MECHANICAL						
15.1 Plumbing			141913	same		141913
15.2 Boilers/burners			5036			20845
15.3 Pumps			15250			3826
15.4 Oil tanks	none					6928
15.5 Oil piping, values, etc.	none					1318
15.6 H.W. heating piping			33028			51593
15.7 Values	incl.in 15.6					11022
15.8 Heating specialties			7058			5025
15.9 Radiators & unit heaters			10541			39997

Table A.4 Continued

ITEM	NCFOB			ECB		
	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)
15.10 Sheet Metal			191304			85113
15.11 Insulation			103429			75844
15.12 Fans			10963			32387
15.13 Cooling coils	none					36595
15.14 Condensing units	none					101451
15.15 Refrig. piping & controls	none					21635
15.16 Filters			1195			9900
15.17 Air terminals			90080			167004
15.18 Auto. temp. control			199216			104100
15.19 Balancing & wtr. treat.			16165			10199
15.20 Generator			49657			25030
15.21 Waste ht. wtr. piping			15693	none		
15.22 Chilled wtr. piping			14617	none		
15.23 Condenser wtr. piping			29564	none		
15.24 Pan drain piping			5441	none		
15.25 Heat pump piping			42137	none		
15.27 Heat pumps			30395	none		

Table A.4 Continued

ITEM	NCFOB		ECB			
	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)	QUANTITY	UNIT COST (\$)	TOTAL COST (\$)
15.28 Reciprocating chiller			20946	none		
15.30 Closed circuit coolers			23528	none		
15.31 Fan coil units			11270	none		
15.32 Miscellaneous			33328	same		33328
15.33 Fire protection			<u>93977</u>	same		<u>93977</u>
DIV. 15 total			1195731			944028
DIV. 16 ELECTRICAL						
16.1 Distribution system						
a. Conduit & wire			178352			217350
b. Walker duct			36000	same		36000
c. Switchgear & bus duct			58500			60375
d. Pulling wire			39600			54338
e. Trim & finish			31500	same		31500
f. Panels, switch. & transform			29825			42263
16.2 Lighting fixtures			113400			163013
16.3 Snow melt & pipe tracing			20539	same		20539
16.4 Fire alarm system			18000	same		18000
16.5 Sound system			18000	same		18000

Table A.4 Continued

ITEM	NCFOB		ECB			
	QUANTITY	UNIT COST (\$)	COST (\$)	QUANTITY	UNIT COST (\$)	COST (\$)
16.6 Grndg. & ltg. protection			18000	same		18000
16.7 Equip. connect. HVAC			<u>14465</u>			<u>19320</u>
DIV. 16 total			576181			698698
SUMMARY						
Architectural/Structural			6147122			5706361
Mechanical			1195731			944028
Electrical			<u>576181</u>			<u>698698</u>
Total			7919034			7349087
G.C. Overhead/Profit	7.6%		<u>601847</u>			<u>558531</u>
TOTAL CONSTRUCTION COST			8520881			7907620

Table A.5 '
 Demonstration Items In NCFOB

Item No.	Building		Dollar Cost Differential
	NCFOB	ECB	
8.5	Large area of interior glazing used around monitoring computer room for viewing by the public.	No computer monitoring system.	-3,091
9.3	Two types of acoustical ceiling systems used to demonstrate and comparatively evaluate various light fixtures.	Single system of ceiling and lighting used.	-40,294
10.2	Access flooring required for monitoring computer room.	No monitoring system.	-5,000

Table A.5 Continued

Item	Building		Dollar Cost Differential
	NCFOB	ECB	
15.10	Multiple mechanical system resulted in greater quantity of duct work and control dampers.	Single system resulted.	-106,191
15.18	Multiplicity of systems resulted in more complex temperature control system.	Normal system.	-95,116
15.19	Multiplicity of system resulted in much higher cost of balancing due to complexity.	Normal balancing cost.	-5,966
16.2	Use of several kinds of light fixtures increased the cost estimated to be about 20% of total listed in Table A.4.	Use conventional lighting design.	-9,923

Table A.5 Continued

Building		Dollar Cost Differential
NCFOB	ECB	
None	The cost of the solar energy system ^a has not been included in the estimate	None
	SUBTOTAL COST DIFFERENTIAL	-\$265,581
	GC Overhead/Profit 7.6%	<u>-20,184</u>
	TOTAL COST DIFFERENTIAL	-\$285,765 ^b

^a This is a small system provided to supplement building heating requirements. To date, this solar energy system is not in full operation. This system will be used to measure the effectiveness and efficiency of solar collectors of various manufacturers.

^b This total cost differential is used in Table 2.1.

APPENDIX B

ENERGY USAGE & PRICE DATA

The energy usage and price data are divided into the following categories: (1) NCFOB Actual Energy Usage And Prices; (2) NCFOB Computed Energy Usage; and (3) ECB Computed Energy Usage.

B.1 NCFOB ACTUAL ENERGY USAGE & PRICES

The 1977 actual energy usage and energy prices for the NCFOB are derived from the monthly utility bills submitted to the Region I Office of GSA. Natural gas, fuel oil and electricity bills are included.

Monthly bills for natural gas, as submitted by the Manchester Gas Co., are used to obtain the usage and price data. These bills reflect the actual meter readings of the dates shown in Table B.1.

The price of natural gas in 1977 is \$0.607 per therm or \$6.07 per million Btu.

Billing for the fuel oil was submitted by the Union Petroleum Corporation and monitored for actual usage by GSA operating personnel. These bills were used to provide energy use data presented in Table B.2.

The price of No. 2 fuel oil in 1977 is \$0.40 per gallon or \$2.86 per million Btu.

Monthly electric bills were submitted by the Public Service Co. of New Hampshire. The electricity usage and price data are derived from these bills which reflect the actual meter readings on the dates shown in Table B.3.

Table B.1

Actual Usage Of Natural Gas For The NCFOB In 1977

Billing Date	Unit Purchase (Therms)	Energy Content ^a (10 ⁹ Btu)
1/1 2/12	4,099.6	0.410
2/12 3/10	2,488.8	0.249
3/10 4/11	2,332.2	0.233
4/11 5/11	1,236.2	0.124
5/11 6/13	1,859.3	0.186
6/13 8/09	3,172.1	0.317
8/09 9/14	2,374.2	0.237
9/14 10/13	561.7	0.056
10/13 11/14	641.3	0.064
11/15 12/31	<u>6089.4</u>	<u>0.609</u>
TOTAL	24854.8	2.421

^a One therm is 0.0001×10^9 Btu.

Table B.2

Actual Usage of No. 2 Fuel Oil For The NCFOB In 1977

Month	Units Purchase Gallon	Energy Content ^a x10 ⁹ Btu
January	1,550	0.217
February	570	0.080
July	590	0.083
August	1,010	0.141
September	150	0.021
December	<u>1,850</u>	<u>0.259</u>
TOTAL	5,720	0.801

^a One gallon of No. 2 fuel oil contains approximately 0.00014×10^9 Btu.

Table B.3

Actual Electricity Usage For The NCFOB In 1977

Billing Dates		Units Purchased (kWh)	Energy Content ^a (10 ⁹ Btu)
12/15	1/13	170,800	0.583
1/14	2/11	148,800	0.508
2/11	3/14	136,000	0.464
3/14	4/15	135,200	0.462
4/15	5/16	118,800	0.406
5/16	6/16	130,800	0.447
6/16	7/15	128,400	0.438
7/15	8/16	149,200	0.509
8/16	9/15	132,400	0.452
9/15	10/14	102,000	0.348
10/14	11/15	101,600	0.347
11/16	12/14	<u>146,800</u>	<u>0.501</u>
TOTAL		1,600,800	5.465

^a One kWh of electricity contains approximately 0.000003414×10^9 Btu.

The price of electricity in 1977 is \$0.0354 per kWh or \$10.37 per million Btu.

B.2 NCFOB PREDICTED ENERGY USAGE

The following NCFOB energy usage data were extracted from the NBSLD computer run for the final building design, as listed in a report, Tamami Kusuda, James E. Hill, Stanley T. Liu, James P. Barnett and John W. Bean,

Pre-Design Analysis of Energy Conservation Options For A Multi-story Demonstration Office Building, U.S. Department of Commerce, National Bureau of Standards, Building Science Series 78, November 1975.
Weather data for 1962 were used for the computation.

Table B.4

Annual Total Energy Usage For The NCFOB In 10^9 Btu

Month	Usage (10^9 Btu)
1	0.776
2	0.726
3	0.607
4	0.470
5	0.420
6	0.357
7	0.364
8	0.401
9	0.314
10	0.470
11	0.545
12	<u>0.726</u>
TOTAL	6.176

According to data extracted from Figure 26 of the above referenced report, the predicted total annual energy usage of 6.176×10^9 Btu shown in Table B.4 can be divided into the heating energy of 2.290×10^9 BTU and the electrical energy of 3.886×10^9 BTU.

B.3 ECB COMPUTED ENERGY USAGE

The following ECB energy usage data were extracted from the NBSLD computer run number 2, modified, as referred to in the report, Tamami Kusuda, James E. Hill, Stanley T. Liu, James P. Barnett and John W. Bean, Pre-Design Analysis of Energy Conservation Options For A Multi-story Demonstration Office Building, U.S. Department of Commerce, National Bureau of Standards, Building Science Series 78, November 1975. Weather data for 1962 were used for the computation.

For the ECB, the annual energy usage is estimated to be 12.260×10^9 Btu which is composed of 4.983×10^9 Btu for heating and 7.277×10^9 Btu for electricity.

Table B.5

Annual Heating Energy For The ECB In 10^9 Btu

Month	Function		Total
	Space Heating	Hot Water	
1	1.083	.037	1.120
2	0.992	.032	1.024
3	0.515	.037	0.552
4	0.197	.035	0.232
5	0.133	.037	0.170
6	0	.035	0.035
7	0	.033	0.033
8	0	.038	0.038
9	0	.032	0.032
10	0.189	.038	0.227
11	0.437	.035	0.472
12	<u>1.015</u>	<u>.033</u>	<u>1.1048</u>
TOTAL	4.561	.422	4.983

Table B.6
Annual Electricity Usage For The ECB In 10⁹ Btu

Month	Function					Total
	Cooling	Fans	Pumps	Lighting	Misc.	
1	.002	.043	.069	0.373	.069	0.556
2	.001	.037	.062	0.323	.060	0.483
3	.022	.043	.069	0.373	.069	0.576
4	.066	.041	.066	0.357	.066	0.596
5	.144	.043	.069	0.373	.069	0.698
6	.183	.041	.019	0.357	.069	0.669
7	.183	.040	.018	0.339	.063	0.643
8	.214	.045	.021	0.391	.072	0.743
9	.140	.037	.017	0.323	.060	0.577
10	.099	.045	.069	0.391	.072	0.676
11	.016	.041	.066	0.357	.066	0.546
12	<u>.001</u>	<u>.040</u>	<u>.069</u>	<u>0.339</u>	<u>.063</u>	<u>0.514</u>
TOTAL	1.073	.500	.613	4.297	.794	7.277

Appendix C

YEAR-BY-YEAR PRESENT VALUE COSTS

The following data are the year end present value costs of owning and operating (energy consumption only) the NCFOB and ECB calculated with various combinations of energy consumption and energy price increase explained in Sections 2.0 and 3.0. These data form the basis of Figures 3.1 through 3.4.

Table C.1

Present Value Cost Of The NCFOB At Year End (\$1000)

Year	Combination 1 1977 Consumption & GSA Price Rise	Combination 2 1977 Consumption & FEA Price Rise	Combination 3 1962 Consumption & GSA Price Rise	Combination 4 1962 Consumption & FEA Price Rise
1976	\$8235.00	\$8235.00	\$8235.00	\$8235.00
1977	8302.01	8302.01	8284.27	8284.27
1978	8372.67	8363.61	8336.23	8329.61
1979	8447.18	8420.25	8391.03	8371.33
1980	8525.76	8472.35	8448.81	8409.73
1981	8601.48	8520.27	8504.49	8445.09
1982	8674.45	8564.35	8558.15	8477.65
1983	8744.76	8604.93	8609.86	8507.63
1984	8812.52	8642.27	8659.68	8535.25
1985	8877.81	8676.64	8707.70	8560.71
1986	8940.73	8708.30	8753.96	8584.16
1987	9001.37	8737.45	8798.55	8605.79
1988	9059.79	8764.30	8841.51	8625.72
1989	9116.09	8789.04	8882.92	8644.11
1990	9170.35	8811.84	8922.81	8661.07
1991	9222.63	8832.57	8961.26	8676.49
1992	9273.01	8851.41	8998.31	8690.51
1993	9321.56	8868.54	9034.01	8703.25
1994	9368.34	8884.11	9068.41	8714.83
1995	9413.43	8898.27	9101.56	8725.36
1996	9456.87	8911.14	9133.51	8734.94
1997	9498.73	8922.84	9164.29	8743.64
1998	9539.07	8933.47	9193.95	8751.55
1999	9577.95	8943.14	9222.54	8758.74
2000	9615.41	8951.93	9250.09	8765.28
2001	9651.50	8959.92	9276.63	8771.23
2002	9686.29	8967.19	9302.21	8776.63
2003	9719.81	8973.79	9326.86	8781.54
2004	9752.11	8979.80	9350.61	8786.01
2005	9783.24	8985.25	9373.50	8790.07
2006	9813.23	8990.22	9395.56	8793.76
2007	9842.14	8994.73	9416.82	8797.12
2008	9869.99	8998.83	9437.30	8800.17
2009	9896.83	9002.56	9457.03	8802.94
2010	9922.70	9005.94	9476.05	8805.46
2011	9947.62	9009.03	9494.38	8807.75
2012	9971.64	9011.83	9512.04	8809.84
2013	9994.78	9014.37	9529.06	8811.73
2014	10017.1	9016.69	9545.46	8813.45
2015	10038.6	9018.79	9561.27	8815.02
2016	10059.3	9020.70	9576.50	8816.44

Table C.2

Present Value Costs Of The ECB At Year End (\$1000)

Year	Combination 1 1977 Consumption & GSA Price Rise	Combination 2 1977 Consumption & FEA Price Rise	Combination 3 1962 Consumption & GSA Price Rise	Combination 4 1962 Consumption & FEA Price Rise
1976	\$7908.00	\$7908.00	\$7908.00	\$7908.00
1977	8013.73	8013.73	8004.09	8004.09
1978	8125.22	8111.10	8105.42	8092.59
1979	8242.80	8200.80	8212.28	8174.11
1980	8366.79	8283.44	8324.97	8249.21
1981	8486.27	8359.60	8433.56	8318.43
1982	8601.40	8429.80	8538.20	8382.22
1983	8712.35	8494.53	8639.04	8441.04
1984	8819.26	8554.22	8736.21	8495.28
1985	8922.29	8609.27	8829.85	8545.31
1986	9021.57	8660.06	8920.08	8591.46
1987	9117.24	8706.93	9007.03	8634.06
1988	9209.43	8750.20	9090.82	8673.37
1989	9298.27	8790.14	9171.56	8709.66
1990	9383.88	8827.02	9249.36	8743.17
1991	9466.37	8860.55	9324.34	8773.64
1992	9545.87	8891.04	9396.59	8801.33
1993	9622.47	8918.75	9466.21	8826.51
1994	9696.29	8943.94	9533.30	8849.40
1995	9767.43	8966.84	9597.95	8870.21
1996	9835.98	8987.66	9660.25	8889.13
1997	9902.03	9006.59	9720.29	8906.32
1998	9965.68	9023.79	9778.14	8921.96
1999	10027.00	9039.44	9833.89	8936.17
2000	10086.10	9053.66	9887.61	8949.09
2001	10143.10	9066.58	9939.37	8960.84
2002	10198.00	9078.34	9989.26	8971.51
2003	10250.90	9089.02	10037.3	8981.22
2004	10301.80	9098.73	10083.7	8990.05
2005	10351.00	9107.56	10128.3	8998.07
2006	10398.30	9115.59	10171.3	9005.36
2007	10443.90	9122.89	10212.8	9011.99
2008	10487.80	9129.52	10252.7	9018.02
2009	10530.20	9135.55	10291.2	9023.50
2010	10571.00	9141.03	10328.3	9028.48
2011	10610.30	9146.02	10364.0	9033.01
2012	10648.20	9150.55	10398.5	9037.13
2013	10684.70	9154.67	10431.7	9040.87
2014	10719.90	9158.41	10463.6	9044.27
2015	10753.80	9161.82	10494.5	9047.37
2016	10786.50	9164.91	10524.2	9050.18

Table C.3

Present Value Costs Of The ECB At Year End (\$1000)

Year	Combination 1A Adjusted 1977 Consumption & GSA Price Rise	Combination 2A Adjusted 1977 Consumption & FEA Price Rise
1976	\$7908.00	\$7908.00
1977	8038.69	8038.69
1978	8176.52	8159.06
1979	8321.86	8269.94
1980	8475.13	8372.10
1981	8622.82	8466.24
1982	8765.15	8553.02
1983	8902.30	8633.03
1984	9034.46	8706.80
1985	9161.81	8774.86
1986	9284.54	8837.64
1987	9402.80	8895.58
1988	9516.76	8949.05
1989	9626.58	8998.42
1990	9732.40	9044.01
1991	9834.38	9085.45
1992	9932.65	9123.13
1993	10027.30	9157.38
1994	10118.60	9188.52
1995	10206.50	9216.83
1996	10291.30	9242.56
1997	10372.90	9265.96
1998	10451.60	9287.23
1999	10527.40	9306.56
2000	10600.50	9324.14
2001	10670.90	9340.12
2002	10738.70	9354.64
2003	10804.10	9367.85
2004	10867.10	9379.85
2005	10927.80	9390.77
2006	10986.40	9400.69
2007	11042.70	9409.71
2008	11097.10	9417.91
2009	11149.40	9425.36
2010	11199.90	9432.14
2011	11248.50	9438.30
2012	11295.30	9443.90
2013	11340.50	9448.99
2014	11384.00	9453.62
2015	11425.90	9457.83
2016	11466.30	9461.65

REFERENCES

1. American Society of Heating Refrigerating and Air-Conditioning Engineers Inc., ASHRAE Handbook of Fundamentals, New York, 1972.
2. Grant, Eugene L. and Ireson, W. Grant, Principles of Engineering Economy, 5th Edition, New York: The Ronald Press Co., 1970.
3. Isaak, Nicholas and Issak, Andrew, Comparative Cost Study As Built vs. Equivalent Conventional Buildings, Unpublished report contracted by the NBS, contract No. T 73183, October 1975.
4. Isaak, Nicholas and Isaak, Andrew, Designing An Energy Efficient Building: A Case Study, General Services Administration, September 1975.
5. Kusuda, Tamami; Hill, James E.; Liu,, Stanley T.,; Barnnett, James P.; and Bean, John W., Pre-Design Analysis of Energy Conservation Options for a Multi-Story Demonstration Office Building, U.S. Department of Commerce, National Bureau of Standards, Building Science Series 1978, November 1975.
6. The National Archives of the United States, "Energy Audit Procedure: Proposed Rules and Hearing," Federal Register, Vol. 42, No. 73, April 15, 1977.

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET	1. PUBLICATION OR REPORT NO. NBSIR 78-1568	2. Gov't Accession No.	3. Recipient's Accession No.	
4. TITLE AND SUBTITLE Economic Analysis of the Norris Cotton Federal Office Building		5. Publication Date November 1978	6. Performing Organization Code	
7. AUTHOR(S) Phillip T. Chen		8. Performing Organ. Report No.		
9. PERFORMING ORGANIZATION NAME AND ADDRESS NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234		10. Project/Task/Work Unit No.	11. Contract/Grant No.	
12. Sponsoring Organization Name and Complete Address (Street, City, State, ZIP) The Department of Energy Washington, D.C. 20461		13. Type of Report & Period Covered Final	14. Sponsoring Agency Code	
15. SUPPLEMENTARY NOTES				
16. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here.) The Norris Cotton Federal Office Building in Manchester, New Hampshire, has been constructed and occupied by the General Services Administration to demonstrate energy conservation techniques in the design and operations of a contemporary office building. This post-occupancy economic evaluation conducted by the National Bureau of Standards shows that additional construction costs incurred in order to reduce the energy consumption of the building are adequately offset by the present value of the resulting annual energy savings. In the economic model, the actual construction cost and energy consumption of the constructed building are compared with the estimated construction cost and energy consumption of a hypothetical equivalent conventional building. The present value costs of the two buildings are calculated for each year during a 40-year study period.				
17. KEY WORDS (six to twelve entries; alphabetical order; capitalize only the first letter of the first key word unless a proper name; separated by semicolons) Building; construction cost estimation; discounted payback period; economic analysis; economic evaluation; energy conservation; life-cycle costing; present value analysis				
18. AVAILABILITY <input checked="" type="checkbox"/> Unlimited <input type="checkbox"/> For Official Distribution. Do Not Release to NTIS <input type="checkbox"/> Order From Sup. of Doc., U.S. Government Printing Office Washington, D.C. 20402, SD Stock No. SN003-003 <input checked="" type="checkbox"/> Order From National Technical Information Service (NTIS) Springfield, Virginia 22151	19. SECURITY CLASS (THIS REPORT) UNCLASSIFIED	21. NO. OF PAGES 60	20. SECURITY CLASS (THIS PAGE) UNCLASSIFIED	22. Price \$5.25

